

**PERMIT to OPERATE**

9150 FLAIR DRIVE, EL MONTE, CALIFORNIA 91731

M 58084

Operation under this permit must be conducted in compliance with all information included with the initial application and the initial permit conditions. The equipment must be properly maintained and kept in good operating condition at all times. In accordance with Rule 206, this Permit to Operate or copy must be posted on or within 8 meters of equipment.

LEGAL OWNER OR OPERATOR: JERVIS B. WEBB COMPANY
9301 RAYO AVENUE
EQUIPMENT LOCATED AT: SOUTH GATE, CALIFORNIA

APPL. NO. 156673

EQUIPMENT DESCRIPTION AND CONDITIONS:

SPRAY BOOTH, BINKS, FLOOR TYPE, MODEL NO. DD-121399; 15'-0" W. X 23'-10" L. X 9'-0" H., WITH ONE 6'-0" X 23'-0" ANDREA EXHAUST FILTER AND TWO 5 H.P. EACH EXHAUST FANS.

-CONDITIONS-

1. THIS SPRAY BOOTH MUST NOT BE OPERATED UNLESS ALL EXHAUST AIR PASSES THROUGH FILTER MEDIA AT LEAST 2 INCHES THICK.

PAGE 1 OF 2

This initial permit must be renewed by **09/16 ANNUALLY** unless the equipment is moved, or changes ownership. If billing for annual renewal fee (Rule 301 f) not received by expiration date, contact office above.

This permit does not authorize the emission of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules of the Air Quality Management District. This permit cannot be considered as permission to violate existing laws, ordinances, regulations or statutes of other government agencies.

EXECUTIVE OFFICER

BY RAQUEL M. PUERTA

DATE 08/06/87

FILE COPY

SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

CONTINUATION OF PERMIT NO. M 58084
(MUST BE DISPLAYED WITH PERMIT)

APPL NO 156673

-CONDITIONS-

2. A GAUGE MUST BE INSTALLED TO INDICATE, IN INCHES OF WATER, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE EXHAUST FILTERS. IN OPERATION, THE PRESSURE DIFFERENTIAL MUST NOT EXCEED 0.25 INCH OF WATER.
3. THE TOTAL QUANTITY OF COATINGS AND SOLVENTS USED IN THIS EQUIPMENT MUST NOT EXCEED 7 GALLONS IN ANY ONE DAY.
4. THIS EQUIPMENT MUST BE OPERATED IN COMPLIANCE WITH RULE 1107.
5. THE OPERATOR SHALL KEEP ADEQUATE RECORDS TO VERIFY DAILY USAGE. SUCH RECORDS SHALL BE RETAINED FOR A PERIOD OF TWO YEARS.